

## Fire Department Inspection

- Fire extinguishers are required for *each* site. The minimum rating required is "2A 10BC". Food trailers will need a minimum rating of "2A 20BC".
- All extension cords must be grounded (3 wire at least 14 gauge). If they are over 50 feet, extension cords must be 12 gauge. All cords must be UL approved and suitable for intended use. Power strips must have at least a 15 amp breaker.
- All general lighting in tents and public areas *must* have construction covers.
- All outdoor electrical connections *must* have a GFI receptacle. This will be strictly enforced.

THANK YOU FOR YOUR COOPERATION IN  
ADHERING TO THESE FIRE REGULATIONS!



## Electrical Information

Inside spaces are wired to accept a regular 110 volt plug for any lights or projectors you may need. Outdoor concessions should consider proper lighting of your outside booth for night use. Electricians will be on hand to hook up concessions needing electric on a first come, first serve basis. They will be available during our office hours. We thank you in advance for your patience and cooperation. Should you have any electrical difficulties, please alert the concessions office.

## Electrical Tags

All outdoor concessions will be required to mark their cords with an electrical tag provided to you by the concessions office. The tag is merely designed to identify the concession and amps of electricity being drawn. The tag should remain attached to the cord for the duration of the fair. Tags will also be furnished for stock trucks and campers which require electricity hook up.